



Test Verification of Conformity

Verification Number: 2406B0447SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	NORA ELEKTRİK MALZEMELERİ SAN.VE TİC.AŞ Burhaniye Mah. Kanuni Sultan Süleyman Sk. Mabeyin Konakları Sitesi No:4E/1 34676 Üsküdar / İstanbul / TÜRKİYE
Manufacturing site Name&Address:	GAONENGGELE ELECTRICAL SHARES CO., LTD. NO. 258, WEI ERSHI ROAD, YUEQING ECONOMIC & DEVELOPMENT ZONE, YUEQING, ZHEJIANG, CHINA
Product Description:	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Ratings & Principle Characteristics:	Ue= 230/400V or 240/415V~(1P), 230V~ or 240V~(1P+N), 400V~ or 415V~ (2P, 3P, 3P+N, 4P), 50/60Hz In= 1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 63A; B-, C- and D-Type Icn= Ics= 4500A; Icn= Ics= 3000A; Neutral pole is identical to phase pole. Explanation of type designation E***: 1st * denotes the type of instantaneous tripping current: B for B- type, blank for C- type, D for D- type; 2nd * denotes the number of poles: 10 for 1P, 11 for 1P+N, 20 for 2P, 30 for 3P, 31 for 3P+N, 40 for 4P; 3rd * denotes short-circuit capacity: 3 for 3000A, 4 for 4500A. E*** (Details See Ratings & Principle Characteristics)
Models/Type References:	
Brand Name(s):	
Standard(s)/Directive(s):	EN 60 898-1:2019 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2024-04-29 to 2024-06-07, 2024-06-10 to 2024-06-20
Test Report Number(s):	2406B0447SHA-001


Signature

Name: Oliver Wei
Position: Manager
Date: 24 June 2024

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.